

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7320-1574:118 Page 1 of 1

CATEGORY: Speakers

LISTEE: ADT Security Services, Inc., 695 Route 46 West, Suite 200, Fairfield NJ 07004
Contact: Ron Dalton (310) 725-2972

DESIGN: Models ADTG4-S2, ADTG4R-S2, ADTG4-S7, and ADTG4R-S7 speakers.
Models ADTG4-S2VM, ADTG4R-S2VM, ADTG4-S7VM, and ADTG4R-S7VM speaker strobes.
Models ADTG4B and ADTG4RB speaker enclosure backbox. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 25 Vrms or 70 Vrms
 $\frac{1}{4}$ W, $\frac{1}{2}$ W, 1 W, 2 W
Candela: 15cd, 30cd, 75cd, 110cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, Model number, electrical rating, UL label.

APPROVAL: Listed as speakers and speaker/strobes for use with separately listed compatible control unit. Speakers with a strobe are suitable for the hearing impaired. For indoor use only.

If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition is required, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

XLf: 7320-1388:243

08-13-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **AUGUST 13, 2002**

Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager